
Requirements for PV plants connected to German MV Distribution System

Dr.- Ing. Gunter Arnold
Fraunhofer IWES
Institute for Wind Energy and Energy Systems Technology
www.iwes.fraunhofer.de

PV/Storage Inverter Communication Workshop,
4th International Integration Conference,
Albuquerque, December 6th, 2010

OUTLINE

- Introduction to Fraunhofer IWES
- Introduction / background to DER grid supporting requirements
- Requirements for DER plants connected to the German MV distribution system
- Approval of grid behaviour of DER plants and PV-inverters according to (new) German MV GridCode
- Summary / Outlook

OUTLINE


- Introduction to Fraunhofer IWES
- Introduction / background to DER grid supporting requirements
- Requirements for DER plants connected to the German MV distribution system
- Approval of grid behaviour of DER plants and PV-inverters according to (new) German MV GridCode
- Summary / Outlook

Fraunhofer Society - Facts and Figures

- Fraunhofer is the largest organization for applied research all over Europe
- More than 80 research subsidiaries with 60 Fraunhofer institutes located all over Germany
- 17 000 employees, most of them with education in science or engineering
- 1,5 billion Euros research budget annually

Fraunhofer Institute for Wind Energy and Energy System Technology (IWES)

- **Foundation:** 1.1. 2009
- **Personal:** ≈ 240 scientists (170 full-time equiv.)
- **Directors:** Prof. Dr. Jürgen Schmid (KS),
Prof. Dr. Andreas Reuter (Bhv)
- **Formerly:**
 - Institute for Solar Energy Supply Technology - ISET in Kassel
 - Fraunhofer Center for Wind Energy and Offshore Technology (CWMT) in Bremerhaven
- **Research Spectrum:**
 - Wind energy from material development to grid optimization
 - Energy system technology for all renewables



Fraunhofer IWES and associated partner universities

Fraunhofer Institute for Wind Energy and Energy System Technology IWES

Location

Bremerhaven

- mechanical engineering
- material science
- offshore measurement technology
- technical reliability

Location Hannover

- construction engineering

Location Oldenburg

- aerodynamics

Location Kassel

Competence fields

- electrical engineering
- control technics
- energy system technology
- electrical grid technology and information processing

Research Association Wind Energy

Research Association of the Partner Universities



Drive Engineering



Civil Engin.




Physics of the Wind



Electrical Engin.

ForWind Association Germany North West

Main Business fields of IWES



- Wind energy technology and operating control
- Elasticity and dynamics of turbines and components
- Competence center for rotor blades
- Development of rotors, drive trains and foundations
- Environmental analysis for wind and ocean energy
- Control and grid integration of decentralized converters
- Energy management and grid operation
- Energy supply structures and systems analysis

OUTLINE

- Introduction to Fraunhofer IWES
- Introduction / background to DER grid supporting requirements
- Requirements for DER plants connected to the German MV distribution system
- Approval of grid behaviour of DER plants and PV-inverters according to (new) German MV GridCode
- Summary / Outlook

Background for DER grid supporting requirements in DE


■ Today's situation:

Very strong increase of DER plants connected to the distribution system

PV: > 16 GWp with 15 - 20% at MV-grid, 80 - 85 % at LV-level

■ **Targets:** Further massive installation of DER together with long term assurance of network stability

■ **Action needed:** DER units and plants connected to German distribution system must be equipped with grid supporting features



Background for DER grid supporting requirements

- **Regulations in the German renewable energies act (EEG 2009)**
 - <http://www.eeg-aktuell.de/>
 - Pre-condition for connection: Fulfilling of technical minimum standards concerning grid behaviour (§6)
 - Link to GridCodes
 - Approval of Conformity by certificates (§64)
- **DistributionCode „DER plants connected MV distribution grid“ (2008)**
 - Techn. requirements for DER plants (steady state / transient) at PCC
 - Basic procedure for approval of conformity
 - Link to Technical Guidelines of FGW for verification of requested grid behaviour
- **Technical Guidelines of FGW**

OUTLINE

- Introduction to Fraunhofer IWES
- Introduction / background to DER grid supporting requirements
- Requirements for DER plants connected to the German MV distribution system
- Approval of grid behaviour of DER plants and PV-inverters according to (new) German MV GridCode
- Summary / Outlook

Overview of BDEW DistributionCode

■ Steady state requirements:

- Limitation of power-quality characteristic parameters (voltage change, harmonics, flicker)
- Active power control (reduction)
- Reactive power control
- Protection functions ($U \ll$, $<U$, $U >$, $f <$, $f >$)


■ Transient behaviour:

- Fault-ride-through (FRT) capability during voltage dips
- No change of active power generation
- Feed-in of reactive power during the fault
- Limitation of short-circuit current contribution




Reactive power control / provision

- Main limiting factor for grid integration of DER plants is the violation of the voltage change (rise) of $2\%U_n$ due to feed-in of active power.
- DER units / plants should be able to provide at least reactive power with a displacement factor $\cos \varphi$ between 1 and 0.95 leading or lagging for grid voltage stabilization under normal operating conditions.
 - Minimal requirement (area between red and magenta lines)
 - Typical for inverter based DER units: (area between blue lines)



Reactive power control / provision

- Reactive power provision according to
 - Setpoint by DSO via remote control or
 - Specified characteristic at PCC
- The following characteristics for Q provision have to be implemented
 - Fixed displacement factor $\cos \varphi$ or
 - Fixed reactive power value or
 - Displacement factor / active power characteristic or
 - Reactive power / voltage characteristic




Active power control

- Active power control (limitation / reduction)
 - Remote active power setpoint control in steps of $\leq 10\%$ by the DSO in case of network congestions or danger of power system collapse.
 - Automatic reduction of active power generation according to a droop characteristic if $f_{\text{grid}} > 50.20\text{ Hz}$ with:

$$P_m = P_{\text{max}} * (1 - 0.4 / (f_{\text{grid}} - 50.2\text{Hz}))$$

- Default setpoints for protection functions
 - Underfrequency trip: $f_{\text{grid}} < 47.5\text{ Hz}$
 - Overfrequency trip: $f_{\text{grid}} > 51.5\text{ Hz}$



Behaviour of DER plants during voltage dips


■ Distinction between two DER types:

- Direct connected synchron. generators (type 1)
- All other generators (type 2)

■ DER behaviour depends mainly on two quantities:


- Depths of voltage dip
- Fault duration

→ Four different requirements



Reactive current feed-in during voltage dips

- DER plants have to feed-in additional reactive current according to a specified characteristic:
 - Value depends on depths of voltage dip and reactive power setpoint prior to fault
 - k-Factor ($k = \Delta I_b / I_n / \Delta U / U_n$) > 2.0 p.u.
 - Definition of characteristic (ΔU) is different according to GridCode
 - TransmissionCode 2007 (TC 2007)
 - System Service Ordinance for Wind Energy plants (SDLWindV)
- Control response time: ≤ 20 msec
- Max. reactive current: $I_b \leq 1.0 I_n$
- Max. duration of reactive current feed-in: Fault clearance + 500msec
- Tripping of overvoltage protection must be avoided (unsymmetrical voltage dips)



OUTLINE


- Introduction to Fraunhofer IWES
- Introduction / background to DER grid supporting requirements
- Requirements for DER plants connected to the German MV distribution system
- Approval of grid behaviour of DER plants and PV-inverters according to (new) German MV GridCode
- Summary / Outlook

Distinction between DER unit ↔ DER plant

DER unit (EZE)

Single device for generation of electricity


- e.g. one WTG or
- Part of a PV-plant, which is connected to one inverter!
- $S_A \leq 1$ MVA (only unit certificate necess.)
- $l_{PCC} \leq 2$ km (only unit certificate)




DER plant (EZA)

Farm / cluster with at least one but normally more DER units (EZE) and


- All equipment, necessary for grid connected operation of the DER plant
 - Farm cabling, substation, trafo, farm controller & other power cond. devices such as filters etc.



Approval procedure for grid connection




Time schedule for approval of grid behaviour




Technical Guidelines of FGW

- FGW working committees developed Technical Guidelines for WTG since 1992
- FGW Guidelines are ground-breaking for international standardization of WTG
→ e.g. IEC 61400 - 21
- Following FGW-TR documents are relevant for approval of grid behaviour:
 - Part 3: Testing and measurement of DER units
 - Part 4: Modeling and validation of DER units and DER plants
 - Part 8: Certification of DER units and DER plants



FGW Technical Guidelines Part 3 (FGW-TR3)

- FGW-TR3 describes measurement methods and test procedures for approval of the grid behaviour of DER units according to the MV-DistributionCode (valid: Rev.19, 14.1.2009)
- FGW-TR3 was developed in the past only for WTG → Measurements and tests according to IEC 61400-21
- Latest Rev. 19 should also be suitable for other DER technologies (PV, Biomass, Hydro)
→ Determination of PV specific test procedures was a very important task!
- FGW working group FGW AK-PV (chaired by IWES) is in charge of this!



FGW Technical Guidelines Part 8 (FGW-TR8)

- Accredited (IEC 45011) certification body evaluates the conformity of DER units / DER plants with the requirements of MV DistributionCode based on:
 - Manufacturer's certificate,
 - Test reports accord. to FGW-TR3
 - Validated models accord. to FGW TR4
 - Simulation results of DER plant
- FGW TR8 includes:
 - General regulations (application, approval, validity, withdrawal of certificates etc.)
 - Evaluation contents and -criteria accord. to the MV DistributionCode

F.2 Einheiten-Zertifikat	
LOGO Zertifizierungsstelle Akreditiert nach EN 45011 – ISO / IEC Guide 65	LOGO
Einheiten-Zertifikat	Nr: 2009-n Unterzeichnete Kopie No. 1
Hersteller	
Typ Erzeugungseinheit	
Technische Daten	Nennleistung:
	Bemessungsspannung:
	Nennfrequenz:
Netzanschlussregel	BDEW-Richtlinie „Erzeugungsanlagen am Mittelspannungsnetz Richtlinie für Anschluss und Parallelbetrieb von Erzeugungsanlagen am Mittelspannungsnetz, Ausgabe Juni 2008
Mitgeltende Normen/ Richtlinien	DIN EN 61400-21; FGW-Richtlinie TR 3
Die oben bezeichnete Erzeugungseinheit erfüllt die Anforderungen der BDEW-Richtlinie „Erzeugungsanlagen am Mittelspannungsnetz“, Ausgabe Juni 2008. Der Hersteller hat die Zertifizierung seines Qualitätsmanagementsystems nach ISO 9001 nachgewiesen.	
Das Zertifikat beinhaltet folgende Angaben: <ul style="list-style-type: none"> • technische Daten der Erzeugungseinheit, der eingesetzten Hilfseinrichtungen und der verwendeten Softwareversion; • den schematischen Aufbau der Erzeugungseinheit; • zusammengefasste Angaben zu den Eigenschaften der Erzeugungseinheit. 	
Ort, Datum (TT.MM.JJJJ)	
Dieses Zertifikat darf nicht in Ausschnitten verwendet werden. LOGO Zertifizierungsstelle, Adresse, e-mail	

Results of working committee AK-PV for FGW-TR3


■ Solar module independent testing:

- Measurements/tests of a PV unit (inverter) should be performed either on-site but also inside a lab with „appropriate“ simulators
- Using Simulators for testing leads to major simplifications
- TR3 „Annex E“ describes the requested characteristics of the DC-Source (PV-simulator)
- Revised Manufacturer's certificate on specific data of PV-units in Annex A
- Important Task: Improvement of PV specific tests for testing of transient behaviour (Chapter 4.7.) Rev. 20 and Rev. 21



Testing of DER units grid behaviour at IWES


- IWES established in 2008 in DeMoTec a Test-lab for Testing accord. to MV DistributionCode and FGW-TR 3
- Accreditation of the Test-lab accord. to IEC 17025
- IWES is performing such grid compatibility tests accord. to German MV DistributionCode since Q3/2009
- Test equipment in DeMoTec: (Limited to DER units with appr. ≤ 100 kVA rated power)



IWES - Test Field for Smart Grids und E-Mobility

SysTec – Outdoor Test Field and Lab for Smart Grids and E-Mobility located in Fuldata near Kassel

- Real electricity grids (MV-, LV-level)
- Real PV units, small WTGs, hybrid systems and typ. customer loads
- E-Mobility: Charging stations, roller type test bench and test road
- Tests of large inverters
- 6 MVA FRT test facility



OUTLINE

- Introduction to Fraunhofer IWES
- Introduction / background to DER grid supporting requirements
- Requirements for DER plants connected to the German MV distribution system
- Approval of grid behaviour of DER plants and PV-inverters according to (new) German MV GridCode
- Outlook

Summary / Outlook

Performed Tasks:

- Manufacturer of DER units: Additional effort (financial & human resources) for adaptation / further development of Inverter
- Test-Labs: Development of new PV-specific Test procedures
- Significant investments concerning new powerful test facilities (MW range)

Outstanding Issues:

- Certification bodies: Increasing the capacities for DER plant certification
- Release of the new German LV GridCode
- Harmonisation (European / Global) of GridCodes and testing standards

Outcomes:

- Important innovations for PV Inverter and other DER plant technologies (similar to the development of WTG approx. 7-8 years ago)
- Stable network operation with significant higher share of power generation by DER and PV plants in distribution networks is achievable

Thank's a lot for your Attention!



Hintergrundbild: pixelio.de | Rainer Sturm